

2021 MAY 28 AM 7:44



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

H: de - H: way water System

Public Water System Name

SS0013

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	Em: ledon 5-26-2021 ms: ledon 5-27-2021
<input type="checkbox"/> Email message (Email the message to the address below)	
<input checked="" type="checkbox"/> Other H: de - H: way water Echoes - June 2021 edition of our monthly newsletter - put on web and email sent	5-25-2021
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL):	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input checked="" type="checkbox"/> Posted in public places (attach list of locations) Copies in office lobby: 510 East Lakeshore Drive, Corvise, MS 39224	5-25-2021
<input checked="" type="checkbox"/> Posted online at the following address (Provide Direct URL): https://www.hawins.com/f/CCR20.pdf	5-24-2021

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Name

Title

Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)

Email: water.reports@msdh.ms.gov

MSDH, Bureau of Public Water Supply

Fax: (601) 576-7800

(NOT PREFERRED)

P.O. Box 1700

Jackson, MS 39215

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2020 Drinking Water Quality Report

HIDE-A-WAY WATER SYSTEM

James Fretwell, Certified Water Operator
Bruce Devillier, General Manager
PWS ID #MS0550013 Pearl River County
510 E. LAKESHORE DR. CARRIERE, MS 39426
www.hawllms.com office@hawllms.net
601-798-1484

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water concerns. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

Our water comes from three (3) wells (Well #2, Well #3, and Well #4) that draw ground water from the Miocene Series Aquifer.

Source water assessment and its availability:

Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?

Our board meets on the **second WEDNESDAY evening of every month. Meetings start at 6:30 p.m. at the Hide-A-Way Lake Club House.** We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Saturday in July at 10:00 a.m. at the Hide-A-Way Lake Club House. This is a very important meeting in which all customers are encouraged to attend. If you have any questions or concerns, you may contact the HAWL Office during business hours (Monday – Friday, 8:00 am – 4:30 pm) at 601-798-1484 or by email at office@hawllms.net.

Other information:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following addresses: <http://www.healthymms.com> or <https://pws.mswater.us>. Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply may be obtained.

Water Quality Data Table

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data though representative of the water quality may be more than one year old.

Total Coliform

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. All results showed all samples free of total coliform.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hide-A-Way Water System is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

Terms and Abbreviations used in the Table of Test Results

MCLG: Maximum Contaminant Level Goal - is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL: Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
AL: Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
ND: Non-detect.

TEST RESULTS						
Contaminant	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
Inorganic Contaminants						
Antimony (ppm) Well #2 Well #3 Well #4	0.006 0.006 0.006	0.006 0.006 0.006	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Arsenic (ppm) Well #2 Well #3 Well #4	0 0 0	0.010 0.010 0.010	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium (ppm) Well #2 Well #3 Well #4	2 2 2	2 2 2	0.0058 0.0011 0.0064	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits.
Beryllium (ppm) Well #2 Well #3 Well #4	0.004 0.004 0.004	0.004 0.004 0.004	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
Cadmium (ppm) Well #2 Well #3 Well #4	0.005 0.005 0.005	0.005 0.005 0.005	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
Chromium (ppm) Well #2 Well #3 Well #4	0.1 0.1 0.1	0.1 0.1 0.1	0.0024 0.0022 0.0023	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from steel and pulp mills; erosion of natural deposits.
Copper (mg/l)	1.3	AL = 1.3	0.1	01/01/15 – 12/31/17 (Triennial)	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. 11 samples collected.
Cyanide (ppm) Well #2 Well #3	0.2 0.2	.2 .2	0.015 0.015	05/06/19 05/06/19	NO NO	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
Fluoride (mg/l) Well #2 Well #3 Well #4	4 4 4	4 4 4	0.243 0.138 0.228	09/04/18 12/02/19 03/24/20	NO NO NO	No fluoride is added to water system.
Haloacetic Acids (ppb) (HAA5) Well #2, Well #3, and Well #4	N/A	60.0 60.0	22.0 14.0	10/07/20 09/29/20	NO	By-product of drinking water disinfection.
Lead (mg/l)	0	AL = .015	0.001	01/01/18 – 12/30/20 (Triennial)	NO	Corrosion of household plumbing systems; erosion of natural deposits. 10 samples collected on 08/04/20.
Mercury (inorganic) (ppm) Well #2 Well #3 Well #4	0.002 0.002 0.002	0.002 0.002 0.002	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
Nitrate (as Nitrogen) (ppm) Well #2 Well #3 Well #4	10 10 10	10 10 10	0.08 0.08 0.08	04/13/20 04/13/20 04/13/20	NO NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
Nitrite (as Nitrogen) (ppm) Well #2 Well #3 Well #4	1 1 1	1 1 1	0.02 0.02 0.02	04/13/20 04/13/20 04/13/20	NO NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
Radium Well #4	5	5	0.5	01/16/18	NO	Radioactive metal that occurs naturally in trace amounts in rocks and soil.
Selenium (ppm) Well #2 Well #3 Well #4	0.05 0.05 0.05	0.05 0.05 0.05	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Sodium (pph) Well #2 Well #3 Well #4	N/A N/A N/A	250.000 250.000 250.000	73.000 65.000 64.000	09/16/19 09/16/19 09/16/19	NO NO NO	Road salt, water treatment chemicals, water softener, and sewage effluents.
Thallium (ppm) Well #2 Well #3 Well #4	0.002 0.002 0.002	0.002 0.002 0.002	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories.
TTHM (Total trihalomethanes) (pph) Well #2, Well #3, and Well #4	N/A	80.0 80.0	21.3 22.6	10/07/20 09/29/20	NO	By-product of drinking water disinfection.
Uranium Well #4	0	30	0.5	11/02/20	NO	Erosion of natural deposits.
Disinfection By-Products						
Chlorine (mg/l)	4.0	4.0	1.40	01/01/20 – 12/31/20	NO	Water additive used to control microbes. MRDL range 1.00 MG/L to 2.20 MG/L.
Microbiological Contaminants	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
# Total Coliform	0	>1	ND	Monthly	NO	Naturally present in the environment.
Units Description: (ppm): parts per million, or milligrams per liter (mg/L). (ppb): parts per billion, or micrograms per liter (µg/l). (pCi/l): picocuries per liter (a measure of radioactivity). % of monthly positive samples: Percent of samples taken monthly that were positive						

Hide Away Lake

From: Hide Away Lake
Sent: Wednesday, May 26, 2021 1:05 PM
To: [redacted]
Subject: Monthly Billing Statement [redacted]
Attachments: [redacted]_Statement_5/25/2021.PDF; Water Rate Increase Notice.pdf; Hot Topics 05-25-2021.pdf

Hide-A-Way Lake Club, Inc.

Attached is your new monthly billing statement for May 2021 . It is due on the 25th.

If you are not enrolled for automatic payments, please click here to submit a manual payment:
<http://billing.hawlms.net:6060/>

Please call the HAWL office at 601-798-1484 if you have any questions about your bill.

Thank you.

Statement Of Account

Remit To HIDE-A-WAY LAKE CLUB, INC.
P.O. BOX 1011
PICAYUNE, MS 39466

(601) 798-1484

Date: May 25, 2021

Account: 0002

Amount Due: \$150.51

Bill To HAROLD & RACHEL VICKNAIR
103 EAST LAKESHORE DRIVE
CARRIERE, MS 39426

Due Date: June 25, 2021

Amount Paid:

Check Number:

Document No.	Date	Code	Description	Amount	Balance Due
	4/25/2021	BBF	Balance Brought Forward	\$154.82	\$154.82
AEFT20215250002	5/1/2021	PMT	Payment	(\$154.82)	\$0.00
00025/25/2021M1	5/25/2021	SLS	13000-8560=4440 WATER	\$17.24	\$17.24
00025/25/2021PF	5/25/2021	SLS	Sewage Processing Fee	\$1.00	\$18.24
00025/25/2021S	5/25/2021	SLS	13000-8560=4440 SEWAGE	\$34.07	\$52.31
0002CAP-RSV000000224	5/25/2021	SLS	CAPITAL RESERVE	\$15.00	\$67.31
0002GAR-FEE000000224	5/25/2021	SLS	GARBAGE FEE	\$14.49	\$81.80
0002OP-FEE000000224	5/25/2021	SLS	OPERATIONAL FEE	\$68.71	\$150.51
Total Amount Due:					\$150.51

2020 Drinking Water Quality Report (CCR 2020) is now available in the HAWL office, upon request & online (<https://www.hawlms.com/f/CCR20.pdf>).

HIDE-A-WAY LAKE CLUB, INC.

Lot # 0002

Date: 5/25/2021

Current	1 - 30 Days	31 - 60 Days	61 and Over
\$150.51	\$0.00	\$0.00	\$0.00

BBF Balance Brought Forward

SLS Sales / Invoices

DR Debit Memos

FIN Finance Charges

CR Credit Memos

PMT Cash Receipts

Hide Away Lake

From: listserver@hawlms.com
Sent: Tuesday, May 25, 2021 2:24 PM
To: office@hawlms.com
Subject: June Echoes Now Available on HAWL's Website

The June edition of Echoes is now available on HAWL's website for viewing! Click the following link (https://www.hawlms.com/f/June_2021_Echoes.pdf) to see the most recent edition or visit HAWL's website and click on the Echoes tab.

Physical copies for Property Owners will be available in the HAWL Office, Front Main Gate, and Southgate by the end of next week.

Be sure to let your friends and neighbors know that by signing up for the weekly email newsletter, you will know as soon as the latest edition of Echoes is available!

To Subscribe, unsubscribe, suspend delivery or opt-out of further promotional mailings go to <http://www.hawlms.com/subscriptions/manage.htm?email=office@hawlms.com>

To read our Privacy Policy go to:
<http://www.hawlms.com/privacy/policy.htm>



Hide-A-Way Lake Echoes

June 2021

Important Security Information

During the months of June and July, all traffic violation fines will be doubled. The goal is to create awareness of roadway safety, not to collect fines. Please help to control speeding, stop sign violations, and distracted driving for the safety and well-being of all our property owners, residents, and guests.



Mediterranean Night

Join Waters Edge on Saturday, June 5, 2021, from 5:00 pm – 8:00 pm for a Mediterranean Special which includes: Mediterranean chickpea salad, spanakopita (spinach pie), shrimp and feta saganaki, Mediterranean seasoned grilled fish, and baklava for dessert for \$16.99 per person. Reservations are required for this special and can be made by calling the Office at 601-798-1484. Full menu will be available.



Steak Dinner & LIVE Entertainment

On Saturday, June 19, 2021, from 5:00 pm – 8:00 pm Waters Edge will host Steak Night with Entertainment. Diners will enjoy a deliciously prepared steak with loaded potato casserole, soup, salad, a roll, and a dessert. The cost is \$16.99 per person. During your meal laugh the night away while enjoying Jim Chester's Senior Moment show which combines award winning comedic magic and music. The musical selection will feature hilariously reimagined songs such as "I Fell Down, I Can't Get Up" to the tune of Elvis's "I'm All Shook Up". The entertainment will take place between 6:30 pm – 7:30 pm at no additional cost. Reservations are required by June 18, 2021, for ordering purposes and can be made by calling the Office at 601-798-1484. No menu items will be available.



Father's Day Lunch

Join Waters Edge on Sunday, June 20, 2021, from 11:00 am - 2:00 pm for a Father's Day Lunch. Enjoy a fried chicken plate (two pieces of white or dark meat), corn on the cob, baked beans, and coleslaw. \$12.99 for an adult's plate and \$6.50 for a kid's plate (one piece of chicken). Reservations must be placed by Friday, June 18, 2021. This delicious meal is available for dine-in or to-go. If selecting the to-go option, meals must be picked up on Sunday, June 20, 2021, between 10:45 am - 11:00 am and then from 1:00 pm - 1:15 pm. (Please indicate your pick-up time when ordering so it will be ready when you arrive.) Reservations can be made by calling the HAWL Office at 601-798-1484. *No menu items will be available for purchase.



Community Meet and Greet with the General Manger

On Saturday, June 26, 2021, join HAWL's General Manager Bruce Devillier for a Community Meet and Greet at 9:30 am in Waters Edge Restaurant (upstairs of the Lodge). This face-to-face collaboration with property owners will provide the opportunity to ask questions to the General Manager directly. This is a great time to ask any questions to prevent the spread of misinformation and to meet some of your neighbors as great neighbors make great communities. While new property owners are highly encouraged to attend, everyone in HAWL is welcome. If you wish to discuss individual matters such as an issue with a neighbor or a complaint, contact the General Manager directly at the Office to set up an appointment.



HAWL Burger Special

Following the Community Meet and Greet with the General Manager on June 26, 2021, enjoy any Waters Edge burger, anyway you want it, with French fries or chips for \$7.99 from 11:00 am - 2:00 pm.



2020 Drinking Water Report

The **2020 Drinking Water Report** (CCR 2020) for HAWL's water system is now available. This report is on the HAWL website under the "Water System" tab and can be located directly at: <https://www.hawlims.com/f/CCR20.pdf>. Copies are also available in the HAWL Office. Additionally, you may also call the Office (601-798-1484) to request that a copy be mailed to you.



Important Water Rate Change

See page 3 of this *Echoes* for an important water rate change.

July 4th Weekend in HAWL

See page 12 of this *Echoes* for all of the fun, family friendly activities planned in HAWL for the July 4th Weekend (July 3rd and 4th).



CCR 2020
put on web
on 5-24-2021

Hide-A-Way Lake Club, Inc.

Water System

- [Home](#)
- [Rules](#)
- [Property Owner's Manual](#)
- [Associates](#)
- [Board of Directors](#)
- [Building Codes](#)
- [Committees](#)
- [Contact Us](#)
- [Events](#)
- [Forms](#)
- [Homesites in HAWL](#)
- [HAWL Properties for Sale](#)
- [HAWL Boat](#)
- [Hours of Operation](#)
- [Informational Links](#)
- [Map of HAWL](#)
- [Memorial Tree Fund](#)
- [Photo Albums](#)
- [Resident](#)
- [Scheduling](#)
- [Tennis](#)
- [Tennis Center](#)
- [Tennis Club](#)
- [Tennis Pro](#)

Water System

- [Hide-A-Way Water System Customer Service Policies and Ordinances](#)
- [2015 Drinking Water Quality Report \(CCR 15\)](#)
- [2016 Drinking Water Quality Report \(CCR 16\)](#)
- [2017 Drinking Water Quality Report \(CCR 17\)](#)
- [2018 Drinking Water Quality Report \(CCR 18\)](#)
- [2019 Drinking Water Quality Report \(CCR 19\)](#)
- [2020 Drinking Water Quality Report \(CCR 20\)](#)

Hide-A-Way Lake Club, Inc. • 601-798-1484 • Fax 601-798-0604
P.O. Box 1011 • Piquette, MS 39466

<https://www.hawls.com/f/CCR20.pdf>

2020 Drinking Water Quality Report
HIDE-A-WAY WATER SYSTEM

James E. Smith, General Manager
Bruce Davitt, General Manager
P.O. Box 1011, Piquette, MS 39466
601-798-1484 • Fax 601-798-0604
www.hawls.com • office@hawls.net

Is my water safe?
Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?
Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water concerns. EPA Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?
Our water comes from three (3) wells (Well #2, Well #3, and Well #4) that draw ground water from the Miocene Series Aquifer.

Source water assessment and its availability.
Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?
Our board meets on the second WEDNESDAY evening of every month. Meetings start at 6:30 p.m. at the Hide-A-Way



Hide-A-Way Lake Club, Inc.

[Home](#)

Water System

[Echoes](#)

[Property Owner's
Manual](#)

[Hide-A-Way Water System Customer Service Policies and Ordinances](#)

[Amenities](#)

[2015 Drinking Water Quality Report \(CCR 15\)](#)

[Board of Directors](#)

[2016 Drinking Water Quality Report \(CCR 16\)](#)

[Building Codes](#)

[2017 Drinking Water Quality Report \(CCR 17\)](#)

[Committees](#)

[2018 Drinking Water Quality Report \(CCR 18\)](#)

[Contact Us](#)

[2019 Drinking Water Quality Report \(CCR 19\)](#)

[Events](#)

[2020 Drinking Water Quality Report \(CCR 20\)](#)

[Forms](#)

**Hide-A-Way Lake Club, Inc. * 601-798-1484 * Fax 601-798-0604
P.O. Box 1011 * Picayune, MS 39466**

[Happenings In HAWL
Email](#)

[HAWL Properties for
Sale](#)

[HAWL Staff](#)

[Hours of Operation](#)

[Informational Links](#)

[Maps of HAWL](#)

[Memorial Tree Fund](#)

[Photo Albums](#)

[Restaurant](#)

[Scholarship
Foundation](#)

[Security Corner](#)

[Social Clubs](#)

[Swimming Pool](#)

[Video - HAWL
Community](#)

[Water System](#)

2020 Drinking Water Quality Report

HIDE-A-WAY WATER SYSTEM

James Fretwell, Certified Water Operator
Bruce Devillier, General Manager
PWS ID #MS0550013 Pearl River County
510 E. LAKESHORE DR. CARRIERE, MS 39426
www.hawlms.com office@hawlms.net
601-798-1484

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water concerns. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

Our water comes from three (3) wells (Well #2, Well #3, and Well #4) that draw ground water from the Miocene Series Aquifer.

Source water assessment and its availability:

Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?

Our board meets on the second WEDNESDAY evening of every month. Meetings start at 6:30 p.m. at the Hide-A-Way Lake Club House. We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Saturday in July at 10:00 a.m. at the Hide-A-Way Lake Club House. This is a very important meeting in which all customers are encouraged to attend. If you have any questions or concerns, you may contact the HAWL Office during business hours (Monday – Friday, 8:00 am – 4:30 pm) at 601-798-1484 or by email at office@hawlms.net.

Other information:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following addresses: <http://www.healthymms.com> or <https://pws.mswater.us>. Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply may be obtained.

Water Quality Data Table

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data though representative of the water quality may be more than one year old.

Total Coliform

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. All results showed all samples free of total coliform.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hide-A-Way Water System is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

Terms and Abbreviations used in the Table of Test Results

MCLG: Maximum Contaminant Level Goal - is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL: Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
AL: Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
ND: Non-detect.

TEST RESULTS						
Contaminant	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
Inorganic Contaminants						
Antimony (ppm) Well #2 Well #3 Well #4	0.006 0.006 0.006	0.006 0.006 0.006	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Arsenic (ppm) Well #2 Well #3 Well #4	0 0 0	0.010 0.010 0.010	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium (ppm) Well #2 Well #3 Well #4	2 2 2	2 2 2	0.0058 0.0011 0.0064	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits.
Beryllium (ppm) Well #2 Well #3 Well #4	0.004 0.004 0.004	0.004 0.004 0.004	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
Cadmium (ppm) Well #2 Well #3 Well #4	0.005 0.005 0.005	0.005 0.005 0.005	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
Chromium (ppm) Well #2 Well #3 Well #4	0.1 0.1 0.1	0.1 0.1 0.1	0.0024 0.0022 0.0023	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from steel and pulp mills; erosion of natural deposits.
Copper (mg/l)	1.3	AL = 1.3	0.1	01/01/15 – 12/31/17 (Triennial)	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. 11 samples collected.
Cyanide (ppm) Well #2 Well #3	0.2 0.2	.2 .2	0.015 0.015	05/06/19 05/06/19	NO NO	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
Fluoride (mg/l) Well #2 Well #3 Well #4	4 4 4	4 4 4	0.243 0.138 0.228	09/04/18 12/02/19 03/24/20	NO NO NO	No fluoride is added to water system.
Haloacetic Acids (ppb) (HAA5) Well #2, Well #3, and Well #4	N/A	60.0 60.0	22.0 14.0	10/07/20 09/29/20	NO	By-product of drinking water disinfection.
Lead (mg/l)	0	AL = .015	0.001	01/01/18 – 12/30/20 (Triennial)	NO	Corrosion of household plumbing systems, erosion of natural deposits. 10 samples collected on 08/04/20.
Mercury (inorganic) (ppm) Well #2 Well #3 Well #4	0.002 0.002 0.002	0.002 0.002 0.002	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
Nitrate (as Nitrogen) (ppm) Well #2 Well #3 Well #4	10 10 10	10 10 10	0.08 0.08 0.08	04/13/20 04/13/20 04/13/20	NO NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
Nitrite (as Nitrogen) (ppm) Well #2 Well #3 Well #4	1 1 1	1 1 1	0.02 0.02 0.02	04/13/20 04/13/20 04/13/20	NO NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
Radium Well #4	5	5	0.5	01/16/18	NO	Radioactive metal that occurs naturally in trace amounts in rocks and soil.
Selenium (ppm) Well #2 Well #3 Well #4	0.05 0.05 0.05	0.05 0.05 0.05	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Sodium (ppb) Well #2 Well #3 Well #4	N/A N/A N/A	250,000 250,000 250,000	73,000 65,000 64,000	09/16/19 09/16/19 09/16/19	NO NO NO	Road salt, water treatment chemicals, water softener, and sewage effluents.
Thallium (ppm) Well #2 Well #3 Well #4	0.002 0.002 0.002	0.002 0.002 0.002	0.0005 0.0005 0.0005	09/04/18 12/02/19 03/24/20	NO NO NO	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories.
TTHM (Total trihalomethanes) (ppb) Well #2, Well #3, and Well #4	N/A	80.0 80.0	21.3 22.6	10/07/20 09/29/20	NO	By-product of drinking water disinfection.
Uranium Well #4	0	30	0.5	11/02/20	NO	Erosion of natural deposits.
Disinfection By-Products						
Chlorine (mg/l)	4.0	4.0	1.40	01/01/20 – 12/31/20	NO	Water additive used to control microbes. MRDL range 1.00 MG/L to 2.20 MG/L.
Microbiological Contaminants	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
# Total Coliform	0	>1	ND	Monthly	NO	Naturally present in the environment.
Units Description: (ppm): parts per million, or milligrams per liter (mg/l), (ppb): parts per billion, or micrograms per liter (µg/l), (pCi/l): picocuries per liter (a measure of radioactivity), % of monthly positive samples: Percent of samples taken monthly that were positive						